

Letter No. 377

TEC / 2020-21

SINGRAULI, DATE 23-6-20

To,

SHEMFORD FUTURISTIC SCHOOL
BARGAWAN
DISTT. SINGRAULI (M.P.)

Sub :-

Issuance of N.O.C. For N.B.C.

Ref :-

Letter Date 08.06.2020


-----000-----

With reference to the above subject as you stated as per CBSE norms your school has to submit a building completion certificate which has to be issued by PWD as per national building code.

Therefore, as per your request we have visited the above site on date 18.06.2020

Hence, this is to certify that the building is as per requirements mentioned in the check list according to NBC (National Building Code.)

Enclose :- Check list according
To NBC (National Building Code.)


EXECUTIVE ENGINEER
PUBLIC WORK DEPARTMENT
DIVISION SINGRAULI (M.P.)


SINGRAULI, DATE

Letter No.

TEC / 2020-21

Copy to,

1. The District Magistrate, Distt. Singrauli (M.P.)


EXECUTIVE ENGINEER
PUBLIC WORK DEPARTMENT
DIVISION SINGRAULI (M.P.)

Check List according to NBC (National Building Code) for CBSE/ICSE Schools (Class VI to X11) specially w.r.t earth quake and Fire Safety.

Points related to Safety

Check List for School Building		Yes	No
1	Whether the MAP of the Building is made by a registered Architect or Engineer?		
2	Whether the map of the building is approved by local body or authorized officer?	Yes	—
3	Whether the building is more than 3 storied?	—	No
4	Whether measure of the land is more than 1.8 hectares?	0.64	Hect.
5	Whether there is 6.0 M open area around the building?	Yes	—
6	Whether there is facility of parking in the building?	Yes	—
7	Whether the orientation of the building is such a way that there is proper ventilation and circulation of air?	Yes	—
8	What is the width of main approach road?	20 feet	
9	Whether the roof of the building is made of RCC. if not whether fire catching material has been used in making the roof of the building ?	Yes	—
10	Whether the wall of the building is made of brick or stone?	Yes	—
11	Is here any crack in any wall of roof the building?	—	No
12	Whether the height of the roof of the classes is minimum 3.6 M from the floor?	—	No (3.15 M)
13	Whether the width and height of the main entrance of the school are 6.0M and 4.5 M respectively?	Yes	—
14	Whether the area of the window is 10% of the floor? Is there no use of Wood in the window?	Yes	
15	Whether there are 2 doors in the classes?	—	No
16	Whether the minimum measurement of the door of the classes has width 1.0 M and height 2.0M?	Yes	—
17	If the building is 2 storied or more then 2 storied then there is is facility of 2 stair case or not ?	—	No
18	Whether the fire extinguisher and automatic sprinkler installed at the proper place in the building ?	Yes	—
19	Is there facility of fire appliances in the building?	Yes	—
20	Whether students and students evaluated from time to time?	Yes	—
21	Whether the First Aid box has been installed at the appropriate place in the building?	Yes	—

AS
12/06/2020
S/E

Manager

Shemford Futuristic School

AS
18/6/2020
S/DO

AS
Executive Engineer
P.W.D Div Singrauli
Distt. Singrauli (M.P.)

Principa

Shemford Futuristic School